



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

David J. Carlin
Iroquois Central School District
2111 Girdle Road
Elma, NY 14059

10/18/2016

Phone: (716) 652-3000
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 10/3/2016. The results are tabulated on the attached data pages for the following client designated project:

Project ID: PO 170501 NY State Component School Dist.
Elma Primary

The reference number for these samples is EMSL Order #011606461. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011606461
CustomerID:	ICSD25
CustomerPO:	170501
ProjectID:	PO 170501 NY Sta

Attn: **David J. Carlin**
Iroquois Central School District
2111 Girdle Road
Elma, NY 14059

Phone: (716) 652-3000
 Fax:
 Received: 10/03/16 4:02 PM

Project: Elma Primary

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>				
001 EP-RM B4-CRS		9/28/2016		0001				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	3.26	1.00	µg/L	10/6/2016	KB	10/7/2016	EG
002 EP-RM B4-CRS		9/28/2016		0002				
200.8	Lead	4.30	1.00	µg/L	10/6/2016	KB	10/7/2016	EG
003 EP-RM B5-WB		9/28/2016		0003				
200.8	Lead	2.48	1.00	µg/L	10/6/2016	KB	10/7/2016	EG
004 EP-RM B5-RRS		9/28/2016		0004				
200.8	Lead	3.41	1.00	µg/L	10/6/2016	KB	10/7/2016	EG
005 EP-RM B5-CRS		9/28/2016		0005				
200.8	Lead	5.09	1.00	µg/L	10/6/2016	KB	10/7/2016	KB
006 EP-RM B3-CRS		9/28/2016		0006				
200.8	Lead	3.50	1.00	µg/L	10/6/2016	KB	10/7/2016	KB
007 EP-RM B6-CRS		9/28/2016		0007				
200.8	Lead	4.06	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011606461
CustomerID:	ICSD25
CustomerPO:	170501
ProjectID:	PO 170501 NY Sta

Attn: **David J. Carlin**
Iroquois Central School District
2111 Girdle Road
Elma, NY 14059

Phone: (716) 652-3000
 Fax:
 Received: 10/03/16 4:02 PM

Project: Elma Primary

Analytical Results

Client Sample Description 008
 EP-RM B2-CRS **Collected:** 9/28/2016 **Lab ID:** 0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.74	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 009
 EP-RM B7-CRS **Collected:** 9/28/2016 **Lab ID:** 0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.13	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 010
 EP-RM B8-CRS **Collected:** 9/28/2016 **Lab ID:** 0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.21	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 011
 EP-RM B8-RRS **Collected:** 9/28/2016 **Lab ID:** 0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.59	2.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 012
 EP-RM B1-CRS **Collected:** 9/28/2016 **Lab ID:** 0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.85	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 013
 EP-RM A4-RRS **Collected:** 9/28/2016 **Lab ID:** 0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 014
 EP-RM A4-CRS **Collected:** 9/28/2016 **Lab ID:** 0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.75	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011606461
CustomerID:	ICSD25
CustomerPO:	170501
ProjectID:	PO 170501 NY Sta

Attn: **David J. Carlin**
Iroquois Central School District
2111 Girdle Road
Elma, NY 14059

Phone: (716) 652-3000
 Fax:
 Received: 10/03/16 4:02 PM

Project: Elma Primary

Analytical Results

Client Sample Description 015
 EP-RM A3-RRS **Collected:** 9/28/2016 **Lab ID:** 0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.9	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 016
 EP-MENS LAV-RRS **Collected:** 9/28/2016 **Lab ID:** 0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.19	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 017
 EP-WOMENS LAV-RRS **Collected:** 9/28/2016 **Lab ID:** 0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.14	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 019
 EP-FACULTY-GCS **Collected:** 9/28/2016 **Lab ID:** 0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.1	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 020
 EP-SYM OFFICE-RRS **Collected:** 9/28/2016 **Lab ID:** 0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	21.8	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 021
 EP-CAFÉ-GCS **Collected:** 9/28/2016 **Lab ID:** 0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 022
 EP-KITCHEN-KS **Collected:** 9/28/2016 **Lab ID:** 0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.58	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606461
 CustomerID: ICSD25
 CustomerPO: 170501
 ProjectID: PO 170501 NY Sta

Attn: **David J. Carlin**
Iroquois Central School District
2111 Girdle Road
Elma, NY 14059

Phone: (716) 652-3000
 Fax:
 Received: 10/03/16 4:02 PM

Project: Elma Primary

Analytical Results

<i>Client Sample Description</i>				<i>Collected:</i>			<i>Lab ID:</i>		
023 EP-KITCHEN-KS				9/28/2016			0023		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.8	Lead	11.5	1.00	µg/L	10/6/2016	KB	10/7/2016	KB	
024 EP-KITCHEN-KS				9/28/2016			0024		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.8	Lead	7.57	1.00	µg/L	10/6/2016	KB	10/7/2016	KB	
025 EP-WOMENS LAV-RRS				9/28/2016			0025		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.8	Lead	7.06	1.00	µg/L	10/6/2016	KB	10/7/2016	KB	
026 EP-RM C14-CRS				9/28/2016			0026		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.8	Lead	4.11	1.00	µg/L	10/6/2016	KB	10/7/2016	KB	
027 EP-RM C14-RRS				9/28/2016			0027		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.8	Lead	ND	1.00	µg/L	10/6/2016	KB	10/7/2016	KB	
028 EP-RM C1-CRS				9/28/2016			0028		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.8	Lead	4.13	1.00	µg/L	10/6/2016	KB	10/7/2016	KB	
029 EP-RM C1-RRS				9/28/2016			0029		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>	
200.8	Lead	2.95	1.00	µg/L	10/6/2016	KB	10/7/2016	KB	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011606461
CustomerID:	ICSD25
CustomerPO:	170501
ProjectID:	PO 170501 NY Sta

Attn: **David J. Carlin**
Iroquois Central School District
2111 Girdle Road
Elma, NY 14059

Phone: (716) 652-3000
 Fax:
 Received: 10/03/16 4:02 PM

Project: Elma Primary

Analytical Results

Client Sample Description 030
 EP-RM CS-CRS **Collected:** 9/28/2016 **Lab ID:** 0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.08	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 031
 EP-RM C2-RRS **Collected:** 9/28/2016 **Lab ID:** 0031

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.67	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 032
 EP-RM C13-RRS **Collected:** 9/28/2016 **Lab ID:** 0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.38	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 033
 EP-RM C13-CRS **Collected:** 9/28/2016 **Lab ID:** 0033

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.33	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 034
 EP-RM C12-RRS **Collected:** 9/28/2016 **Lab ID:** 0034

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.03	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 035
 EP-RM C12-CRS **Collected:** 9/28/2016 **Lab ID:** 0035

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.79	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 036
 EP-RM C12-WB **Collected:** 9/28/2016 **Lab ID:** 0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.34	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606461
 CustomerID: ICSD25
 CustomerPO: 170501
 ProjectID: PO 170501 NY Sta

Attn: **David J. Carlin**
Iroquois Central School District
2111 Girdle Road
Elma, NY 14059

Phone: (716) 652-3000
 Fax:
 Received: 10/03/16 4:02 PM

Project: Elma Primary

Analytical Results

Client Sample Description 037
 EP-RM C11-RRS **Collected:** 9/28/2016 **Lab ID:** 0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.27	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 038
 EP-RM C11-WB **Collected:** 9/28/2016 **Lab ID:** 0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	14.2	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 039
 EP-RM C11-CRS **Collected:** 9/28/2016 **Lab ID:** 0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.09	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 040
 EP-RM C3-RRS **Collected:** 9/28/2016 **Lab ID:** 0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.66	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 041
 EP-RM 3-WB **Collected:** 9/28/2016 **Lab ID:** 0041

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	18.2	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 042
 EP-RM C3-CRS **Collected:** 9/28/2016 **Lab ID:** 0042

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.5	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 043
 EP-RM C4-CRS **Collected:** 9/28/2016 **Lab ID:** 0043

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.82	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011606461
CustomerID:	ICSD25
CustomerPO:	170501
ProjectID:	PO 170501 NY Sta

Attn: **David J. Carlin**
Iroquois Central School District
2111 Girdle Road
Elma, NY 14059

Phone: (716) 652-3000
 Fax:
 Received: 10/03/16 4:02 PM

Project: Elma Primary

Analytical Results

Client Sample Description 044
 EP-RM C4-RRS
Collected: 9/28/2016 **Lab ID:** 0044

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.42	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 045
 EP-RM C4-WB
Collected: 9/28/2016 **Lab ID:** 0045

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.65	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 046
 EP-WF
Collected: 9/28/2016 **Lab ID:** 0046

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/6/2016	KB	10/8/2016	KB

Client Sample Description 047
 EP-GYM-WF
Collected: 9/28/2016 **Lab ID:** 0047

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.22	1.00	µg/L	10/6/2016	KB	10/8/2016	KB

Client Sample Description 048
 EP-WF
Collected: 9/28/2016 **Lab ID:** 0048

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/6/2016	KB	10/8/2016	KB

Client Sample Description 050
 EP-RM C10-CRS
Collected: 9/28/2016 **Lab ID:** 0050

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	19.9	1.00	µg/L	10/6/2016	KB	10/8/2016	KB

Client Sample Description 051
 EP-RM C10-RRS
Collected: 9/28/2016 **Lab ID:** 0051

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.08	1.00	µg/L	10/6/2016	KB	10/8/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011606461
CustomerID:	ICSD25
CustomerPO:	170501
ProjectID:	PO 170501 NY Sta

Attn: **David J. Carlin**
Iroquois Central School District
2111 Girdle Road
Elma, NY 14059

Phone: (716) 652-3000
 Fax:
 Received: 10/03/16 4:02 PM

Project: Elma Primary

Analytical Results

Client Sample Description 052
 EP-RM C8-RRS **Collected:** 9/28/2016 **Lab ID:** 0052

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/6/2016	KB	10/8/2016	KB

Client Sample Description 053
 EP-RM C8-CRS **Collected:** 9/28/2016 **Lab ID:** 0053

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/6/2016	KB	10/12/2016	KB

Client Sample Description 054
 EP-RM C5-RRS **Collected:** 9/28/2016 **Lab ID:** 0054

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.99	1.00	µg/L	10/6/2016	KB	10/8/2016	KB

Client Sample Description 055
 EP-RM C5CRS **Collected:** 9/28/2016 **Lab ID:** 0055

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.97	1.00	µg/L	10/6/2016	KB	10/8/2016	KB

Client Sample Description 057
 EP-RM C6-CRS **Collected:** 9/28/2016 **Lab ID:** 0057

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.20	1.00	µg/L	10/6/2016	KB	10/8/2016	KB

Client Sample Description 058
 EP-RM C6-RRS **Collected:** 9/28/2016 **Lab ID:** 0058

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/6/2016	KB	10/8/2016	KB

Client Sample Description 059
 EP-RM C7-CRS **Collected:** 9/28/2016 **Lab ID:** 0059

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/6/2016	KB	10/8/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011606461
CustomerID:	ICSD25
CustomerPO:	170501
ProjectID:	PO 170501 NY Sta

Attn: **David J. Carlin**
Iroquois Central School District
2111 Girdle Road
Elma, NY 14059

Phone: (716) 652-3000
 Fax:
 Received: 10/03/16 4:02 PM

Project: Elma Primary

Analytical Results

Client Sample Description 061
 EP-WF **Collected:** 9/28/2016 **Lab ID:** 0061

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/6/2016	KB	10/8/2016	KB

Client Sample Description 062
 EP-BOILER RM-M **Collected:** 9/28/2016 **Lab ID:** 0062

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.87	1.00	µg/L	10/6/2016	KB	10/8/2016	KB

Client Sample Description 063
 EP-BACK FLOW **Collected:** 9/28/2016 **Lab ID:** 0063

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1070	100	µg/L	10/6/2016	KB	10/12/2016	KB

Client Sample Description 064
 EP-WF-CAFÉ HALL **Collected:** 9/28/2016 **Lab ID:** 0064

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.68	1.00	µg/L	10/6/2016	KB	10/12/2016	KB

Definitions:

ND - indicates that the analyte was not detected at the reporting limit
 RL - Reporting Limit (Analytical)