



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

David J. Carlin
Iroquois Central School District
2111 Girdle Road
Elma, NY 14059

10/13/2016

Phone: (716) 652-3000
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 9/30/2016. The results are tabulated on the attached data pages for the following client designated project:

Project ID: PO 170501 NY State Component School Dist.
Marilla Primary

The reference number for these samples is EMSL Order #011606426. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011606426
CustomerID:	ICSD25
CustomerPO:	170501
ProjectID:	PO 170501 NY Sta

Attn: **David J. Carlin**
Iroquois Central School District
2111 Girdle Road
Elma, NY 14059

Phone: (716) 652-3000
 Fax:
 Received: 09/30/16 5:06 PM

Project: **Marilla Primary****Analytical Results**

Client Sample Description 001
 001-MP-RM-12-CRS **Collected:** 9/28/2016 **Lab ID:** 0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	17.0	1.00	µg/L	10/6/2016	KB	10/12/2016	KB

Client Sample Description 002
 002-MP-BOYS LAV-SW-RRS **Collected:** 9/28/2016 **Lab ID:** 0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.04	1.00	µg/L	10/6/2016	KB	10/8/2016	KB

Client Sample Description 003
 003-MP-BOYS LAV-SW-RRS **Collected:** 9/28/2016 **Lab ID:** 0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.64	1.00	µg/L	10/6/2016	KB	10/8/2016	KB

Client Sample Description 004
 004-MP-BOYS LAV-SW-RRS **Collected:** 9/28/2016 **Lab ID:** 0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.60	1.00	µg/L	10/6/2016	KB	10/8/2016	KB

Client Sample Description 005
 005-MP-RM-10-CRS **Collected:** 9/28/2016 **Lab ID:** 0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.65	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 006
 006-MP-RM-9-CRS **Collected:** 9/28/2016 **Lab ID:** 0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	31.1	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 007
 007-MP-GIRLS LAV-SW-RRS **Collected:** 9/28/2016 **Lab ID:** 0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.06	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606426
 CustomerID: ICSD25
 CustomerPO: 170501
 ProjectID: PO 170501 NY Sta

Attn: **David J. Carlin**
Iroquois Central School District
2111 Girdle Road
Elma, NY 14059

Phone: (716) 652-3000
 Fax:
 Received: 09/30/16 5:06 PM

Project: **Marilla Primary**

Analytical Results

Client Sample Description 008
 008-MP-BOYS LAV-SW-RRS **Collected:** 9/28/2016 **Lab ID:** 0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.91	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 009
 009-MP-BOYS LAV-SW-RRS **Collected:** 9/28/2016 **Lab ID:** 0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.30	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 010
 010-MP-RM-15-CRS **Collected:** 9/28/2016 **Lab ID:** 0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.1	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 011
 011-MP-RM-18-CRS **Collected:** 9/28/2016 **Lab ID:** 0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.01	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 012
 012-MP-NURSE LAV-SW-RRS **Collected:** 9/28/2016 **Lab ID:** 0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 013
 013-MP-RM-19-CRS **Collected:** 9/28/2016 **Lab ID:** 0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.08	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 014
 014-MP-KITCHEN-KS **Collected:** 9/28/2016 **Lab ID:** 0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	29.1	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011606426
CustomerID:	ICSD25
CustomerPO:	170501
ProjectID:	PO 170501 NY Sta

Attn: **David J. Carlin**
Iroquois Central School District
2111 Girdle Road
Elma, NY 14059

Phone: (716) 652-3000
 Fax:
 Received: 09/30/16 5:06 PM

Project: **Marilla Primary****Analytical Results**

Client Sample Description 015
 015-MP-KITCHEN-KS **Collected:** 9/28/2016 **Lab ID:** 0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.8	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 016
 016-MP-KITCHEN-KS **Collected:** 9/28/2016 **Lab ID:** 0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.32	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 017
 017-MP-KITCHEN-KS **Collected:** 9/28/2016 **Lab ID:** 0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	65.1	2.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 018
 018-MP-MENS LAV-RRS **Collected:** 9/28/2016 **Lab ID:** 0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4250	500	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 019
 019-MP-WOMENS-LAV-RRS **Collected:** 9/28/2016 **Lab ID:** 0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.57	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 020
 020-MP-WOMENS-LAV-RRS **Collected:** 9/28/2016 **Lab ID:** 0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.41	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 021
 021-MP-FAC RM-GCS **Collected:** 9/28/2016 **Lab ID:** 0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.19	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011606426
CustomerID:	ICSD25
CustomerPO:	170501
ProjectID:	PO 170501 NY Sta

Attn: **David J. Carlin**
Iroquois Central School District
2111 Girdle Road
Elma, NY 14059

Phone: (716) 652-3000
 Fax:
 Received: 09/30/16 5:06 PM

Project: **Marilla Primary****Analytical Results**

Client Sample Description 022
022-MP-LIBRARY-GCS **Collected:** 9/28/2016 **Lab ID:** 0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.22	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 023
023-MP-RM 43-CRS **Collected:** 9/28/2016 **Lab ID:** 0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.98	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 024
024-MP-RM 43-RRS **Collected:** 9/28/2016 **Lab ID:** 0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.83	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 025
025-MP-RM 42-RRS **Collected:** 9/28/2016 **Lab ID:** 0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.4	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 027
027-MP-RM 42-CRS **Collected:** 9/28/2016 **Lab ID:** 0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.0	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 028
028-MP-GIRLS LR-RRS **Collected:** 9/28/2016 **Lab ID:** 0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	22.4	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 029
029-MP-BOYS LR-RRS **Collected:** 9/28/2016 **Lab ID:** 0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	12.4	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011606426
CustomerID:	ICSD25
CustomerPO:	170501
ProjectID:	PO 170501 NY Sta

Attn: **David J. Carlin**
Iroquois Central School District
2111 Girdle Road
Elma, NY 14059

Phone: (716) 652-3000
 Fax:
 Received: 09/30/16 5:06 PM

Project: **Marilla Primary****Analytical Results**

Client Sample Description 030
 030-MP-BOYS LR-WB **Collected:** 9/28/2016 **Lab ID:** 0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.7	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 031
 031-MP-COACHES OFFICES-RRS **Collected:** 9/28/2016 **Lab ID:** 0031

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.00	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 032
 032-MP- RM 41-RRS **Collected:** 9/28/2016 **Lab ID:** 0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.99	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 033
 033-MP-RM 41-WB **Collected:** 9/28/2016 **Lab ID:** 0033

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	15.5	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 034
 034-MP-RM 41-CRS **Collected:** 9/28/2016 **Lab ID:** 0034

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.63	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 035
 035-MP-RM 40-RRS **Collected:** 9/28/2016 **Lab ID:** 0035

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.87	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 036
 036-MP-RM 40-WB **Collected:** 9/28/2016 **Lab ID:** 0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	17.0	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011606426
CustomerID:	ICSD25
CustomerPO:	170501
ProjectID:	PO 170501 NY Sta

Attn: **David J. Carlin**
Iroquois Central School District
2111 Girdle Road
Elma, NY 14059

Phone: (716) 652-3000
 Fax:
 Received: 09/30/16 5:06 PM

Project: **Marilla Primary****Analytical Results**

Client Sample Description 037
 037-MP-RM-40-CRS **Collected:** 9/28/2016 **Lab ID:** 0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	15.3	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 038
 038-MP-RM 39-RRS **Collected:** 9/28/2016 **Lab ID:** 0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.58	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 039
 039-MP-RM 29-WB **Collected:** 9/28/2016 **Lab ID:** 0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	12.8	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 040
 040-MP-RM 29-CRS **Collected:** 9/28/2016 **Lab ID:** 0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.75	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 041
 041-MP-BOYS LAV-RRS **Collected:** 9/28/2016 **Lab ID:** 0041

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.82	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 042
 042-MP-BOYS LAV-RRS **Collected:** 9/28/2016 **Lab ID:** 0042

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.81	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 043
 043-MP-BOYS LAV-RRS **Collected:** 9/28/2016 **Lab ID:** 0043

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.04	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011606426

CustomerID: ICSD25

CustomerPO: 170501

ProjectID: PO 170501 NY Sta

Attn: **David J. Carlin**
Iroquois Central School District
2111 Girdle Road
Elma, NY 14059

Phone: (716) 652-3000
 Fax:
 Received: 09/30/16 5:06 PM

Project: Marilla Primary

Analytical Results

Client Sample Description 044
 044-MP-GIRLS LAV-RRS **Collected:** 9/28/2016 **Lab ID:** 0044

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.43	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 045
 045-MP-GIRLS LAV-RRS **Collected:** 9/28/2016 **Lab ID:** 0045

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.89	1.00	µg/L	10/6/2016	KB	10/7/2016	KB

Client Sample Description 046
 046-MP-GIRLS LAV-RRS **Collected:** 9/28/2016 **Lab ID:** 0046

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.34	1.00	µg/L	10/7/2016	KB	10/10/2016	KB

Client Sample Description 047
 047-MP-RM 32-CRS **Collected:** 9/28/2016 **Lab ID:** 0047

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.5	1.00	µg/L	10/7/2016	KB	10/10/2016	KB

Client Sample Description 048
 048-MP-RM 37-CRS **Collected:** 9/28/2016 **Lab ID:** 0048

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	20.0	1.00	µg/L	10/7/2016	KB	10/10/2016	KB

Client Sample Description 049
 049-MP-RM 36-CRS **Collected:** 9/28/2016 **Lab ID:** 0049

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	17.5	1.00	µg/L	10/7/2016	KB	10/10/2016	KB

Client Sample Description 050
 050-MP-RM 33-CRS **Collected:** 9/28/2016 **Lab ID:** 0050

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.01	1.00	µg/L	10/7/2016	KB	10/10/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011606426
CustomerID:	ICSD25
CustomerPO:	170501
ProjectID:	PO 170501 NY Sta

Attn: **David J. Carlin**
Iroquois Central School District
2111 Girdle Road
Elma, NY 14059

Phone: (716) 652-3000
 Fax:
 Received: 09/30/16 5:06 PM

Project: **Marilla Primary****Analytical Results**

Client Sample Description 051
051-MP-RM 35-CRS
Collected: 9/28/2016 **Lab ID:** 0051

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	37.4	1.00	µg/L	10/7/2016	KB	10/10/2016	KB

Client Sample Description 052
052-MP-RM 34-CRS
Collected: 9/28/2016 **Lab ID:** 0052

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	14.8	1.00	µg/L	10/7/2016	KB	10/10/2016	KB

Client Sample Description 053
053-MP-WF
Collected: 9/28/2016 **Lab ID:** 0053

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.27	1.00	µg/L	10/7/2016	KB	10/10/2016	KB

Client Sample Description 055
055-MP-WF
Collected: 9/28/2016 **Lab ID:** 0055

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.43	1.00	µg/L	10/7/2016	KB	10/10/2016	KB

Client Sample Description 056
056-MP-WF
Collected: 9/28/2016 **Lab ID:** 0056

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.32	1.00	µg/L	10/7/2016	KB	10/10/2016	KB

Client Sample Description 058
058-MP-WF
Collected: 9/28/2016 **Lab ID:** 0058

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.75	1.00	µg/L	10/7/2016	KB	10/10/2016	KB

Client Sample Description 065
065-MP-BLACK FLOW
Collected: 9/28/2016 **Lab ID:** 0065

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	32.6	1.00	µg/L	10/10/2016	LY	10/11/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606426
 CustomerID: ICSD25
 CustomerPO: 170501
 ProjectID: PO 170501 NY Sta

Attn: **David J. Carlin**
Iroquois Central School District
2111 Girdle Road
Elma, NY 14059

Phone: (716) 652-3000
 Fax:
 Received: 09/30/16 5:06 PM

Project: **Marilla Primary**

Analytical Results

Client Sample Description 066 **Collected:** 9/28/2016 **Lab ID:** 0066
 066-MP-NONE-WF

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	15.2	1.00	µg/L	10/7/2016	KB	10/10/2016	KB

Definitions:

ND - indicates that the analyte was not detected at the reporting limit
 RL - Reporting Limit (Analytical)